

## Addendum # 1 -- 12-016.0-CIP -- E-Mail Coversheet 2012 Sanitary Manhole Rehabilitation Project

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Advanced Rehabilitation Technology S	gmockART@metalink.net	Gary Mock
Advanced Underground Inspection	lagarrett@hotmail.com	Lori Garrett
Allied Construction Industries	coakley@aci-construction.org	Candi Oakley
Bid Clerk	cthusat@bidclerk.com	C Thusat
Bid Ocean	eric@bidocean.com	Eric Johnson
Builders Exchange	bpopovic@bxohio.com	Bridget Popovic
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	David Power
Conco Spray Solutions	dricketts@concospray.com	Jennifer Hoop
Construction News Corp.	aab3@cncnews online.com	Ted Blaicher
Construction Video Media	karen@constructionvideomedia.com	Karen Stachkunis
Culy Contracting, INC	craigc@culycontracting.com	Craig Closser
Danbert Inc.	psutton@danbertinc.com	Phil Sutton
Drier & Maller, Inc.	info@dreierandmaller.com	Steve Mailer
F. W. Dodge / McGraw Hill	odge_document_mw@mcgraw-hill.co	Puna Johnson
Flowline L.L.C.	sheavener@flowlinellc.com	Paul Heavener
George J. Igel & Company, Inc.	matt.check@igelco.com	Matthew Check
ISQFT	ohio@isqft.com	Amber Eversole
John Eramo & Sons, Inc.	jason@eramo.com	Jason Hazelbaker

Please sign, date and return by e-mail to [hgeorge@dublin.oh.us](mailto:hgeorge@dublin.oh.us) to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: \_\_\_\_\_ Date: \_\_\_\_\_



Date of Addendum  
**Sep 14, 2012**

**City of Dublin -- Division of Engineering**  
5800 Shier-Rings Road Dublin OH 43016  
Phone (614) 410-4640 Fax (614) 761-650

---

## Addendum # 1 -- 12-016.0-CIP -- E-Mail Coversheet

### 2012 Sanitary Manhole Rehabilitation Project

KIM Construction Company Inc	info@kimconstruction.com	Brett Vallow
Lake County Sewer CO., INC	RICHS@LAKECOUNTYSEWER.COM	Rich Smith
MCSP	mosp@fuse.net	Drew O'Connor
Metropolitan Environmental Services, I	cstepp@metenviro.com	Curly Stepp
Paint BidTracker	bchurray@paintsquare.com	Brian Churray
Paint Square	clange@paintsquare.com	Charles Lange
Pim Corporation	bsalazar@pimcorp.com	Belman Salazar
Prime Vendor	bids1@prime-vendor.com	Laurie Melnick
Proshot Concrete, Inc	patm@proshotconcrete.com	Pat Mooney
Robinson Pipe Cleaning Company	truby@robinsonpipe.com	Chris Truby
Shelly & Sands, Inc.	bcolbert@shellyandsands.com	Betty Colbert
Sherwin Williams	swrep4831@sherwin.com	Dustan Bible
Source Management	sourcemgmt@onvia.net	Source Managemen
Team Fishel	bysmith@teamfishel.com	Brain Smith
Trotter Group	tmartin@trotterconstruction.com	Tim Martin
United Survey, Inc.	usi@unitedsurveyinc.com	Gina Lehigh
Varo Engineers	lsniechowski@varoeng.com	Lenell Sniechowski
Vititoe Construction, Inc.	vititoe@frontier.com	Mike Vititoe
Warren Enviromental	sean@warrenenviro.com	Sean O'Connell

Please sign, date and return by e-mail to [hgeorge@dublin.oh.us](mailto:hgeorge@dublin.oh.us) to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: \_\_\_\_\_ Date: \_\_\_\_\_



Date of Addendum  
**Sep 14, 2012**

**City of Dublin -- Division of Engineering**  
5800 Shier-Rings Road Dublin OH 43016  
Phone (614) 410-4640 Fax (614) 761-650



CITY OF DUBLIN™

ADDENDUM #1 TO THE PROPOSAL AND CONTRACT DOCUMENTS  
FOR  
2012 Sanitary Sewer Manhole Rehabilitation  
12-016-CIP

**Part One. GENERAL**

This addendum covers changes to the Proposal and Contract Documents and becomes a part thereof. Each Bidder shall include these items to the extent they affect his or her Bid. These items modify only the portion of the Documents specifically noted. All other wording and Drawings remain in effect.

**Part Two. PLAN MODIFICATIONS**

A. None

**Part Three. PROJECT MANUAL MODIFICATION**

A. SECTION 4 – SUPPLEMENTAL SPECIFICATION

a. Section SS-10, CEMENTITIOUS MANHOLE REHABILITATION, Page SS10-3

1. Part 2 – PRODUCTS, 2.1 MATERIALS, C. MANHOLE LINER

a. Use "Quadex QM-1S Restore", "Strong Seal MS-2E-A or ~~MS-2C~~" by Strong Seal Systems, Inc., "SewperCoat 2000 HS Regular" by Master Builders, Inc., or approved equal.

**Part Four. RELEVANT QUESTIONS FROM BIDDERS**

A. Can the Manhole Steps be removed and replaced prior to manhole lining? We request this because replacing them after lining as specified, will require that we are drilling and hammering into the new cement liner, thus causing cracks and possible structural damage behind the new liner not visible to the eye.

a. *Response: Yes*

B. Are we to refer to the City of Dublin frame and cover drawing or the City of Columbus frame and cover drawing?

*a. Response: City of Dublin.*

C. In terms of manholes requiring excavation work:(i.e bid item 4,5,6) Does the City have a list of the surface condition for each manhole? How many are located in grass or non paved areas? How many would require asphalt or concrete restoration?

*a. Response: See the maps provided in the bid documents and all contractors are welcome to make a site visit.*

D. In the included manhole rehab repair table, there is a column for Joints/ft. There are not any bid items pertaining to any Joint sealing work? What is the purpose/intent of this column?

*a. Response: The Reconstructed (T.C. to Cone Wall/Joint) (ft.) is in reference to the Reconstructed MH to Grade. This is the depth in which you will have to removed the cone, frame, casting and grade rings in order to reconstruct the manhole.*

E. Does the City have any interior inspection photos of the manholes available?

*a. Response: No*

F. Are we responsible for coating the inverts of the manholes with cement? If so, is that the intent of bid item 2 & 3?

*a. Response: See Standard Drawing MR-1.*

G. If the steps are plastic in the manholes do they still need replaced?

*a. Response: Yes.*

H. Can you clarify Items 8 and 9?

*a. Response: The intent of items 8 and 9 are for additional vertical footage to be performed in the event of the contract coming in under the estimated total cost for material and labor. This will be at the direction of the City Engineer.*

END OF SECTION



Addendum Approved by: \_\_\_\_\_

Date: 9/14/2012

Paul Hammersmith, P.E.  
City Engineer/Director of Engineering

\* \* \* \* \*

Terminus for Addendum No. 1  
Certification by Bidder

Bidder shall sign and date one copy of this Addendum No. 1 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: \_\_\_\_\_

Date: \_\_\_\_\_

Company: \_\_\_\_\_