

Addendum # 1 -- 10-006.0-CIP -- E-Mail Coversheet Dublin Road & Glick Road Intersection Improvements

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Allied Construction Industries	coakley@aci-constructon.org	Candi Oakley
Asplundh Construction Corp.	bdelmonico@asplundh.com	Brian Deimonico
Builders Exchange	ametcalf@bxohio.com	Andrea Metcaff
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	Dave Power
Complete General Construction Comp	estimators@cgclist.com	Anne Rhymer
Danbert Inc.	psutton@danbertinc.com	Phil Sutton
Double Z Construction	vinceguzzo@doublez.co	Vince Guzzo
F. W. Dodge / McGraw Hill	puna.johnson@mhfi.com	Puna Johnson
George J. Igel & Company, Inc.	matt.check@igelco.com	Matthew Check
ISQFT	Ohio@isqft.com	Jenae Coulter
Kokosing Construction	psutton@danbertinc.com	Mary Blue
McDaniels Construction Corp., Inc.	moncrief@mcdanielsconstruction.com	Dan Moncrief III
Park Enterprise Construction Co., Inc.	lingel@parkenterpriseconstruction.co	Tim Klingel
Reed Construction Data	archana.sharma@reedbusiness.com	Archana Sharma
Sachs Masonry	SACHSMASONRY@YAHOO.COM	David Sachs
Shelly & Sands, Inc.	j.schultz@shellyandsands.com	Jeff Schultz
Shelly & Sands, Inc.	bcolbert@shellyandsands.com	Betty Colbert
Strawser Paving Company, Inc.	cstrawser@strawserpaving.com	Corey Strawser

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Jun 16, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 1 -- 10-006.0-CIP -- E-Mail Coversheet
Dublin Road & Glick Road Intersection Improvements

The Shelly Company

rkirk@shellyco.com

Ross Kirk

Trucco Construction Company

joel.cochran@truccoconstruction.com

Joel Cochran

US Utility Contractor Company, Inc.

dtaylor@usutilitycontractors.com

Don Taylor

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Jun 16, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 1
to the contract for**

**Dublin Road / Glick Road Intersection Improvements
10-006-CIP
Bid Date: June 18, 2014**

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

REQUEST FOR INFORMATION

1. *Can the pavement calculations be made available for this project?*
 - a. The excel file generated by the design consultant is being made available on the City's website for download by prospective bidders.
2. *On Sheet 20, a private sign is shown to be relocated. No new location is given. Can you provide details / drawings on the location that is proposed for this sign?*
 - a. See answer for question #3.
3. *Bid Line 40 - Spec - Stone Sign Relocated - 1 EA. Please identify the location of this sign.*
 - a. The general note states that the sign "will be relocated to a new location to be determined by the Engineer". The new location is expected to be between ten (10) and fifteen (15) feet northwest of the sign's current location.
4. *Bid Line 64 - 895* - Manufactured Water Quality Structure, Type 1 - 2 EA. I cannot find a detail on these structures within the plan set. Is this an ODOT WQ-1-1? If so, please provide the riser size and the invert elevation.*
 - a. See the answer for question #5.
5. *The two water quality structures shown on sheet 20 do not have any profiles or details for the structures. Can you tell me what the structure type, depth and size will be for this bid.*
 - a. The manufactured water quality structures are to be in accordance with ODOT Supplemental Specification 895. The Contractor is to choose from the ODOT approved manufacturer list.
6. *This project has the same item for "in cabinet serial communication link" that Baldwin & Sours did not provide a quote. They said that it is "No longer supported".*
 - a. The line item is to be non-performed. Do not bid.

*** Beginning of Sheet 2 ***

* * * * *

Addendum Approved By:



Paul A. Hammersmith, PE
Director of Engineering/City Engineer

06-16-2014
Date

* * * * *

**Terminus for Addendum No. 1
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 1 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____

Date: _____

Company: _____