

Addendum # 1 -- 14-009.0-CIP -- E-Mail Coversheet

Academic Drive - Phase 1

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Allied Construction Industries	coakley@aci-construction.org	Candi Oakley
Asplundh Construction Corp.	bdelmonico@asplundh.com	Brian Delmonico
Bid Clerk	govbids@bidclerk.com	Dan Jackson
Buckeye Ready Mix	khill@buckeyereadymix.com	Kevin Hill
Builders Exchange	ametcalf@bxohio.com	Andrea Metclaf
Cem-Base Inc	isaac@cembase.com	Isaac Whitney
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	David Power
Complete General Construction Comp	estimators@cgclist.com	Anne Rhymer
Danbert Inc.	psutton@danbertinc.com	Phil Sutton
Decker Construction Company	jewert@deckerconstruction.com	Jon Ewert
F. W. Dodge / McGraw Hill	puna.johnson@mhfi.com	Puna Johnson
George J. Igel & Company, Inc.	matt.check@igelco.com	Matthew Check
ISQFT	Ohio@isqft.com	Jenae Coulter
Jess Howard	lauras@jesshoward.com	Laura Snyder
John Eramo & Sons, Inc.	bids@eramo.com	Jason Hazelbaker
McDaniels Construction Corp., Inc.	moncrief@mcdanielsconstruction.com	Dan Moncrief
MHC Dodge	elaine.wilson@mhfi.com	Elaine Wilson
Shelly & Sands, Inc.	bcolbert@shellyandsands.com	Bety Colbert

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Aug 11, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 1 -- 14-009.0-CIP -- E-Mail Coversheet
Academic Drive - Phase 1

Strawser Paving Company, Inc.	cstrawser@strawserpaving.com	Corey Strawser
Terra Valley Excavating	mawalker12@gmail.com	Marquis Walker
Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran
US Utility Contractor Company, Inc.	dtaylor@usutilitycontractors.com	Don Taylor

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Aug 11, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 1
to the contract for
Academic Drive – Phase 1
14-009-CIP
Bid Date: August 14, 2014**

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

REQUEST FOR INFORMATION

1. *This project needs quite a bit of embankment can we excavate the material needed from the future pond? Or do we need to import fill material?*
 - a. The future pond is being constructed by another project and the material excavated is being utilized by that project. Therefore the City's contractor will need to supply fill material.
2. *At the water main tie in can we shut down the existing 16" water main to cut in a new tee? Or do you want to use a 16" x 12" Tapping sleeve & Valve?*
 - a. The Contractor will be permitted to shut down the 16" main in order to cut in a new 16"x12" tee.
3. *ODOT 206 provides a separate line item to pay for Lime Kiln Dust material by the ton, however this item has not been included on the bid form. Is the lime kiln dust material to be included in the square yard item for stabilized subgrade or will a line item for the material be added?*
 - a. Payment for Item 206 – Lime Kiln Dust Stabilized Subgrade, 16" Deep shall include all labor, equipment and materials necessary to complete the work.
4. *The CAD file ZIP folder found in on the webpage below contains PDF files. I am trying to determine if there are CAD files available. Any help you can provide would be appreciated.*
 - a. The PDF files which were mistakenly placed into the ZIP file have been replaced with the correct CAD files.

CLARIFICATION OF GENERL NOTE

The City will accept either reinforced concrete pipe meeting ASTM C-76, Class III or HDPP pipe meeting 920.02, Item 20 for storm sewers 18, 24, 30, 36, 42 and 48 inches in diameter.

*** Beginning of Sheet 2 ***

* * * * *

Addendum Approved By:

Paul A. Hammersmith, PE
Director of Engineering/City Engineer

08-11-2014
Date

* * * * *

**Terminus for Addendum No. 1
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 1 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____

Date: _____

Company: _____