

Addendum # 2 -- 11-021.0-CIP -- E-Mail Coversheet

Frantz Road Utility Burial

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Adleta, Inc.	gcoleman@adletaconstruction.com	Garry Coleman
Allied Construction Industries	coakley@aci-construction.org	Candi Oakley
Bid Clerk	govbids@bidclerk.com	Dan Jackson
Builders Exchange	ametcalf@bxohio.com	Andrea Metcalf
Chagrin Valley Engineering, Ltd	woodard@cvelimited.com	John Woodward
Columbus Asphalt Paving, Inc.	djpower@capasphalt.com	Kevin Power
Complete General Construction Comp	estimators@cgclist.com	Whit Wardell
Construction Journal	aniel.Streen@ConstructionJournal.co	Dan Streen
Construction Journal	ted.blaicher@constructionjournal.com	Ted Blaicher
Danbert Inc.	psutton@danbertinc.com	Phil Sutton
Decker Construction Company	jewert@deckerconstruction.com	Jon Ewert
DODGE Data & Analytics	elaine.wilson@mhfi.com	Elaine Wilson
George J. Igel & Company, Inc.	matt.check@igelco.com	Matthew Check
ISQFT	Jcoulter@isqft.com	Jenae Coulter
J. Ranck Electric, Inc.	jarose@jranck.com	Adam Ranck
Jess Construction Inc.	jessconst1@gmail.com	Derick Bendickson
Jess Howard	lauras@jesshoward.com	Laura Snyder
Kwest Group	jongehle@kwestgroup.com	Jon Gehle

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 17, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 2 -- 11-021.0-CIP -- E-Mail Coversheet
Frantz Road Utility Burial

Shelly & Sands, Inc.	j.schultz@shellyandsands.com	Jeff Schultz
Strawser Paving Company, Inc.	cstrawser@strawserpaving.com	Corey Strawser
Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran
US Utility Contractor Company, Inc.	dtaylor@usutilitycontractors.com	Don Taylor

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 17, 2014

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 2
to the contract for**

**FRANTZ ROAD UTILITY BURIAL
11-021-CIP
Bid Date: November 20, 2014**

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

Request for Information:

1. *Are there any City of Dublin permits required for this project?* Answer: On Sheet 5 of 33, in the General Notes, it states "The City is responsible for obtaining all necessary permits."

CONSTRUCION DRAWINGS

General Notes – Sheet 6 of 33

Delete Note: BACKFILL WITHIN A 1:1 INFLUENCE LINE OF EXISTING STRUCTURES (PAVEMENTS, SIDEWALKS, CURBS, ETC.) SHALL BE ITEM 912, COMPACTED GRANULAR MATERIAL, OR ITEM 636, TYPE 2.

Add Note: BACKFILL WITHIN A 1:1 INFLUENCE LINE OF EXISTING STRUCTURES (PAVEMENTS, SIDEWALKS, CURBS, ETC.) SHALL BE ITEM 613, FCDF, TYPE 2.

Sheet 9 of 33

Clarification -

Power and Communication Duct Trench Details show the MINIMUM depth of required backfill cover, 2'-6" over Time Warner Communication ducts and 3'-0" over AEP ducts.

Trench and Surface Restoration Details require all trenches to have Item 613 FCDF, Type 2 backfill placed between the concrete encased ducts and the bottom of the surface restoration.

Sheet 26 of 33

Concrete Entrance Drive Detail @ Millennium:

Delete Note – INSTALL 4" – SCH. 80 CONDUIT AS SHOWN ON DUBLIN STD. DETAIL RD-07, SHEET 6 OF 9. (NOT SEPARATE PAYMENT).

* * * Beginning of Sheet 2 * * *

* * * * * * * * * * * * *

Addendum Approved By:



Paul A. Hammersmith, PE
Director of Engineering/City Engineer

11-17-2014
Date

* * * * * * * * * * * * *

**Terminus for Addendum No. 2
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 2 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____

Date: _____

Company: _____