

Addendum # 1 -- 16-019.0-CIP -- E-Mail Coversheet

North Fork Indian Run Capacity Improvement

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Allied Construction Industries	coakley@aci-construction.org	Candi Oakley
Builders Exchange	kniemeyer@bxohio.com	Kristin Niemeyer
Cleary Construction, Inc.	estimating@clearyconst.com	Mary Jo Spurlock
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	David Power
Complete General Construction Comp	estimators@cgclist.com	Whit Wardell
ConstructConnect	content@constructconnect.com	Morgan Stinson
Construction Journal	d.dybzinski@constructionjournal.com	Donna Dybzinski
Danbert Inc.	psutton@danbertinc.com	Phil Sutton
Deltek	patriciamanarin@deltek.com	Patricia Manarin
Foill Inc.	kelly@foillinc.com	Kelly Seif
George J. Igel & Company, Inc.	matt.check@igelco.com	Matt Check
McDaniels Construction Corp., Inc.	moncrief@mcdanielsconstruction.com	Dan Moncrief
Midwest Mole Inc	plandesk@midwestmole.com	Amy Webster
Nickolas Savko and Sons	singram@nicksavko.com	Scott Ingram
North America Procurement Council In	lyra@napc.me	Lyra DeAsis
Shelly & Sands, Inc.	n.pence@shellyandsands.com	Nigel Pence
Sunesis Construction Co	astrunk@sunesiscc.com	Andrea Strunk
The Blue Book	kstein@mail.thebluebook.com	Kathy Stein

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 14, 2017

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 1 -- 16-019.0-CIP -- E-Mail Coversheet

North Fork Indian Run Capacity Improvement

Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran
Vortex Infrastructure Holdings	sales@vortexcompanies.com	Michael Reyes
Xylem Dewatering Solutions	mark.moseley@xyleminc.com	Mark Moseley

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 14, 2017

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 1
to the contract for**

**North Fork Sanitary Sewer Capacity Improvements
16-019-CIP**

Bid Date: November 17, 2017

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

GENERAL QUESTIONS:

1. I see per the specs that there is no geotechnical report for this project. Do you have any geo-reports from previous projects in the area? We really need more information for the installation of the 24" storm that goes under the existing 24" sanitary. We need to know where the rock starts and the level of the ground water for the remaining work in this project.

Response: No geotechnical information is available for this project or previous projects in the area.

2. Bid Item #14 Filter sock-the bid tab sheet has both base and alternate listed as per each. Shouldn't these items be linear foot? Please clarify.

Response: Item 207 Filter Sock should be in linear foot, and has been corrected in the revised bid schedule.

3. Will there be a prebid meeting?

Response: No, there will not be a prebid meeting.

4. Please clarify what the asphalt items are for? Temporary drive to parking lot or pavement repair on Kilgour Place, or both? If it is for pavement restoration for Kilgour Place, please revise the quantities?

Response: Asphalt items should include both the temporary drive and pavement repair for base bid and alternate. Corrected quantities are as follows:

<i>304 Aggregate Base</i>	<i>113 Cubic Yards</i>
<i>448 Intermediate Course</i>	<i>49 Cubic Yards</i>
<i>448 Surface Course</i>	<i>39 Cubic Yards</i>

These item quantities are reflected in the revised bid schedule.

5. Bid item #11 Excavation and Embankment – Is this for the excavation for temporary driveway pavement? If not please clarify where is this work is taking place and how much of each?

Response: Yes, excavation and embankment are for the temporary driveways.

* * * Beginning of Sheet 2 * * *

- 6. Under which bid item should we put the cost for the tree protection fence?
Response: Tree protection fencing should be included as part of Item 207-Construction Fence.

CLARIFICATIONS

BID SCHEDULE

The Landscaping Items (Items 659 and 661) have been removed from both the base bid and alternate bid estimated quantities. A revised bid schedule has been provided.

* * * * *

Addendum Approved By:

Paul A. Hammersmith, PE
Director of Engineering/City Engineer

11-14-2017
Date

* * * * *

**Terminus for Addendum No. 1
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 1 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____

Date: _____

Company: _____

BID SCHEDULE

BIDDER agrees to perform all work described in the CONTRACT DOCUMENTS for the following unit prices:

**NORTH FORK SANITARY SEWER CAPACITY
IMPROVEMENTS
16-019-CIP**

CITY OF DUBLIN

REF NO.	(1) ITEM	(2) DESCRIPTION	(3) QUANT.	(4) UNIT	(5) LABOR(\$)	(6) MATERIAL(\$)	(7) (5)+(6) TOTAL(\$)	(8) (3) X (7) TOTAL EXTENDED INFORMAL PRICE(\$)
GENERAL								
1	201	CLEARING AND GRUBBING	1	LUMP				
2	201	TREE REMOVED, 18" SIZE	3	EA.				
3	201	TREE REMOVED, 30" SIZE	2	EA.				
4	201	TREE REMOVED, 48" SIZE	1	EA.				
5	202	PIPE REMOVED	72	L.F.				
6	202	PAVEMENT REMOVED	505	S.Y.				
7	202	CONCRETE COLLAR REMOVED	1	EA.				
8	202	MANHOLE REMOVED	1	EA.				
9	202	SIGN REMOVED FOR REUSE	1	EA.				
10	202	LIGHT POLE REMOVED FOR REUSE	3	EA.				
11	203	EXCAVATION AND EMBANKMENT	28	C.Y.				
12	204	SUBGRADE COMPACTION	505	S.Y.				
13	207	CONSTRUCTION FENCE	3670	L.F.				
14	207	FILTER SOCK	3231	L.F.				
15	252	FULL DEPTH PAVEMENT SAWING	376	L.F.				
16	254	PAVEMENT PLANING, ASPHALT CONCRETE	420	S.Y.				
17	304	AGGREGATE BASE	113	C.Y.				
18	408	PRIME COAT	51	GAL.				
19	448	ASPHALT CONCRETE SURFACE COURSE, TYPE 1, PG64-22	39	C.Y.				
20	448	ASPHALT CONCRETE INTERMEDIATE COURSE, TYPE 1, PG64-22	49	C.Y.				
21	604	MANHOLE (AA-S102, TYPE C)	1	EA.				
22	623	CONSTRUCTION LAYOUT STAKES	1	LUMP				
23	624	MOBILIZATION AND GENERAL CONDITIONS	1	LUMP				
24	901	18" PIPE WITH TYPE 1 BEDDING	2026	L.F.				
25	901	24" PIPE WITH TYPE 1 BEDDING	12	L.F.				
26	901	24" PIPE WITH TYPE 1 BEDDING, WATER TIGHT JOINTS AND TRENCH DAMS	60	L.F.				
27	901	30" X 18" PIPE WITH TYPE 1 BEDDING	30	L.F.				
28	614	MAINTENANCE OF TRAFFIC	1	LUMP				
29	642	EDGE LINE, SOLID (WHITE)	0.11	MILE				
30	642	CENTER LINE, DOUBLE SOLID (YELLOW)	0.04	MILE				
31	661	SEEDING AND MULCHING	4188	S.Y.				
					SANITARY SEWER SUBTOTAL =			
SUBMITTED BY (COMPANY): _____					TOTAL BASE BID (REF. #'s 1 - 31) =			

