

# SOLAR INSTALLATIONS AT THE SERVICE CENTER

## ADDENDUM NO. 2

For: Solar Installations at the Service Center RFP

Due Date: March 28, 2024 4:00 P.M. (EST)

**To prospective consultants: the following information shall be used to clarify parts of the request for proposals.**

### Supplemental Information Request

Who is the utility provider? **AEP**

What is the roof material? Is it standing seam metal? **It is both. Flat membrane roof for a section on the western wing and metal on the southernmost portion of the eastern wing.**

Is the roof warrantied? **The majority of the roof is out of warranty. The southernmost portion of the eastern wing is still under warranty.**

What is the service voltage? 208V or 480V? **480 and 208.**

Where is the utility meter located? **It is located on the far west side of the building and is accessed from the north parking lot.**

Where is the Main Service Panel located? **In the western wing.**

