

From: [Wilson, Douglas H.](#)
To: [Megan Cyr](#); [Clouse, Michael J.](#)
Cc: [Katie Freeland](#)
Subject: RE: Darree Fields Water
Date: Wednesday, August 10, 2022 3:07:40 PM

[EXTERNAL]

Hi Megan:

Joe and I talked and we do not need to do a normal plan review for this site as all work is after the 4" city water meter and it's backflow preventer.

We would like to ask for a copy of the proposed water service plan (after Dublin approves) for our records retention.

Many thanks

Doug

From: Megan Cyr [mailto:Megan.Cyr@kleingers.com]
Sent: Tuesday, August 9, 2022 8:39 AM
To: Clouse, Michael J. <MJClouse@Columbus.gov>
Cc: Katie Freeland <kfreeland@msaarch.com>; Wilson, Douglas H. <DHWilson@Columbus.gov>
Subject: [EXTERNAL] RE: Darree Fields Water

Good morning,

Just following back up on this. I'm looking to confirm if we would need to submit a WSP to Columbus for review and approval.

Thanks,
Megan

Megan Cyr, PE, LEED AP

THE KLEINGERS GROUP

C: 513.255.5804

From: Megan Cyr
Sent: Thursday, August 4, 2022 8:49 AM
To: 'mjclouse@columbus.gov' <mjclouse@columbus.gov>
Cc: Katie Freeland <kfreeland@msaarch.com>
Subject: Darree Fields Water

Joe,

We are just beginning to look at a project with City of Dublin at Darree Fields. They plan to construct a new concession and restroom building. I understand from the City of Dublin that the planned water service connection is downstream of the master meter for the park. Can you please confirm that a water service plan is not required for extension of the private lines after the master meter for the park?

Thanks,
Megan

Megan Cyr, PE, LEED AP
Project Manager

THE KLEINGERS GROUP
350 Worthington Road, Suite B
Westerville, Ohio 43082
C: 513.255.5804



SPORTWORKS DESIGN | A division of The Kleingers Group