

From: [John Burchett](#)
To: [James Condo](#)
Cc: [Sarah Holt](#)
Subject: RE: Paint Colors
Date: Friday, April 12, 2024 10:58:54 AM

The old House will have a 5 1/4 hardie with 4in exposure and the new building will have 8 ¼ hardie with 7in exposure. So you will be able to see a difference between old and new. Yes window trim will be replaced with hardie trim to match the paint scheme. Paint will be SW 6208 on the trim on the old building and main color on the new. SW7005 will be the main color on the old building and trim on the newer building.

From: [John Burchett](#)
To: [James Condo](#)
Subject: RE: Hardie Trim
Date: Wednesday, April 17, 2024 12:42:01 PM

It will be 5/4 smooth hardie trim.

