

**ADDENDUM NO. 1
to the RFP for**

**CA/CI RFP-Northern Historic District Infra. Impv. 25-029-CIP
25-029-CIP**

RFP Due Date: January 20, 2026

TO PROSPECTIVE CONSULTANTS: The following changes shall be made part of the contract documents for this project:

Question: Could you provide additional clarification on the requirements you are looking for the Asphalt Level 2 position? Are you looking for an actual asphalt lab tech to run lab testing (rice, voids, density etc.), or are you looking for a plant monitor, or both?

Answer: The Level 2 Asphalt QC certification is desired for any required asphalt testing performed by laboratory personnel. Asphalt installed with the project should be following the CMSC 448 specification.



Addendum Approved By:

Paul A. Hammersmith, PE

Director of Engineering/City Engineer

01-09-2026

Date

* * * * *

**Terminus for Addendum No. 1
Certification by Consultant**

Consultant shall sign and date one copy of this Addendum No. 1 and submit with their proposal as evidence of receipt and evaluation of same in their proposal.

Signed: _____

Date: _____

Company: _____