

FILE COPY

RECEIVED
FEB 19 2019
CITY OF DUBLIN
PLANNING

Stoneridge Outpatient Care -- Monument Sign



Outpatient Care Stoneridge -- Photo Renderings



10/2/19

2019 South County
Public Works
01/24/2019

eyetrack

RECEIVED
FEB 19 2019
CITY OF DUBLIN
PLANNING

FILE COPY



RECEIVED
FEB 19 2019
CITY OF DUBLIN
PLANNING

FILE COPY

Stoneridge Outpatient Care -- Monument Sign



02/19/19

Outpatient Care Stoneridge -- Photo Renderings

2017 Road Library, Inc.
Photo Rendering
02/19/19

eyetooth

FILE 0017

RECEIVED



Existing Sign Locations



Outpatient Care Stromeridge -- Location Plan



Proposed Locations



1-22-19

1800 Grandview Blvd
Dublin, CA 94568
916.331.1100

eyethink


RECEIVED
FEB 19 2019
CITY OF DUBLIN
PLANNING

FILE COPY

Transl. Black on First Surface
 Clear Showing Thru to Transl. White on Second Surface



6' (72") OA Cabinet
 5' (60") Alum Face
 6"



Numbers coped from alum face backed with illuminated white acrylic

Illuminated Push-Thru Acrylic Block O

Opaque Vinyl

Illuminated Push-Thru Acrylic 5/16" Letter Caps


Exposed concrete color: Dark Gray Pre Mix Buff Wash Finish

Concrete Base

3 1/2 x 3 1/2 x 1/4" steel tube

concrete footer - 48" depth x 74" wide x 15" thick center pole sign mount

Electric - 110/220v



Monument Sign - D/F

Aluminum clad cabinet & reveal constructed over welded aluminum framework.
 Address numbers - routed into face panels & backed up with translucent acrylic.
 Dimensional panels - 125" aluminum construction with 2" returns. Panels secured flush to cabinet with concealed fasteners.

*Block O's - shape routed thru panel & backed up with 1" thick, push-thru clear acrylic.
 Translucent black & red vinyl are applied to first surface & translucent white vinyl applied to second surface. Illuminated thru the face & around perimeter for soft halo glow.
 Logo type text & underscore - opaque, non-illuminated vinyl applied directly to panels.

*Outpatient Care - routed thru panel & backed up p95 binary black/white translucent acrylic.
 All routed/ acrylic text & symbols illuminated with white LED light clusters housed in cabinet.

120 ac electrical feed brought to site by others. Cabinet return fitted with external electric disconnect, weatherproof box with switch.

Cabinet secured to 3 1/2" x 3 1/2" x .25" steel sq tube set into concrete slab foundation - 36" x 60" deep.
 Poured concrete base & sub-grade footer—all top & side corner edges are chamfered to 1" @ 45 degree angle.

Color:

Cabinet - Matthews Red
 Mathews Akzo 408-ES (High Gloss) (Alt. MP 1026)
 Dimensional panels - map stain silver faces & returns.
 Metallic Silver; Akzo 359-A4
 Block O - clear acrylic with translucent black & translucent red pms#200 vinyl applied to first surface. Translucent white vinyl applied second surface.
 Logo type text & underline - opaque, non-illuminated nimbus gray vinyl applied.
 Outpatient Care - binary black/white acrylic.
 Reveal - black/dark gray.
 Led light clusters - white.
 Concrete - dark gray color.

2017 OBC - ASCE 7-10
 - Wind Load - Risk Category II: 150 mph
 - Seismic: 0.25
 - Exposure: B
 - Class 4 Soil with
 Lateral Bearing = 140 psf/ft



15555 SW Shawnee Sign/Art Files/081 WMC - Dublin Outpatient

Ohio State University
Monument Sign
 01/25/19



Project Layout
 Approved
 Approved as Noted

3900 Stoneridge Lane,
 Dublin, OH 43017

Sales: MH
 Design: SH
 Dwg: 19-022

Approval Signature

155 E. Fifth Ave. Columbus, OH 43219 P: (614)252-3133

FILE COPY




RECEIVED

FEB 19 2019

CITY OF DUBLIN
PLANNING



Proposed - Entrance #1



Entrance #1

Entrance #2

Directional Signs (Non-Illuminated) D/F

- 2x2 alum tube frame
- .125" aluminum frame
- direct buried installation

Color:

Cabinet - Matthews Red
 Mathews Akzo 408-E5 (High Gloss) (Alt. MP 10/26)
 Dimensional panels - matt stain silver faces & returns.
 Metallic Silver, Akzo 359-A4
 Logotype text - opaque, non-illuminated nimbus gray vinyl applied.



2017 OBC - ASCE 7-10
 Wind Load - Risk Category II
 Speed - V₅₀ = 90 mph
 Class 4 Soil with
 Lateral Bearing = 150 psf/ft

\\SSS\SSS\Signs\At File\OSU\MKC - Dublin\Outpatient

2

Scales: MH
 Design: SH
 Dwg: 19-022

Project Layout
 Approved
 Approved as Noted

3900 Stoneridge Lane,
 Dublin, OH 43017

Ohio State University
 Directional Signs
 01/25/19



Approval Signature

1515 E. Fifth Ave. Columbus, OH 43219 P: (614)252-3133

RECEIVED
 FEB 19 2019
 CITY OF DUBLIN
 PLANNING

FILE 0077




5'-/- set back


10'-/- set back

8'-/- set back

remove existing sign



Entrance #1



Entrance #2



3

Sales: MH
 Design: SH
 Dwg: 12-022

Project Layout
 Approved
 Approved as Noted

3900 Stoneridge Lane,
 Dublin, OH 43017

Approval Signature

**Ohio State University
 Monument Sign**
 02/12/19



COLUMBUS SIGN COMPANY
 1515 E. Fifth Ave. Columbus, OH 43219 P: (614)252-3133



New Monument Sign

Directional Sign

Directional Sign

Move location to other side of driveway

STONERIDGE

PUBBLIN CENTER

Columbus GIS

273009146

273012290

273012289

3905

273009149

R.O.W.

R.O.W.

R.O.W.

10'±

5'±

EXISTING SIGN

SET BACK 2'

12' R.O.W.








Location modified - See revised drawing




117 OBC - ASCE 7-10
 Wind Load - Risk Category II
 Speed - V₅₀ = 90 mph
 Exposure B
 Class 4 Soil with
 Lateral Bracing - 150 psf



Entrance #1



Entrance #2



Ohio State University
Monument sign
 01/25/19



Project Layout
 Approved
 Approved as Noted

3900 Stoneridge Lane,
 Dublin, OH 43017

Approval Signature _____

Sales: MH
 Design: SH
 Dwg: 19-022

3

