

AN EQUIVALENT GRIPPING SURFACE. THE HAND GRIP PORTION OF HANDRAILS SHALL HAVE SMOOTH SURFACE W/ NO SHARP EDGES THE STAIR TREADS WILL BE AT LEAST 9" DEEP, AND THE RISE WILL NOT EXCEED 8 1/4" PER STEP. A MIN. HEAD ROOM OF 6'-8" WILL BE MAINTAINED. PORCHES, BALCONIES OR RAISED FLOORS LOCATED MORE THAN 30" ABOVE THE FLOOR OR GRADE SHALLHAVE GUARDRAILS NOT LESS THAN 36" HIGH OPEN STAIRS WITH RISE OF MORE THAN 30", SHALL HAVE GUARDRAIL NOT LESS THAN 34" HIGH. JOISTS UNDER PARALLEL BEARING PARTITION SHALL BE DOUBLED OR A BEAM OS ADEQUATE SIZE TO SUPPORT THE

SPINDLES LOCATED AT A MAX. OF 4" O.C.. HAND GRIP PORTION SHALL NOT BE MORE THAN 2 5/8" IN CROSS

SECTION DIM. OR AN APPROPRIATE SHAPE WHICH SHALL PROVIDE

LOAD SHALL BE PROVIDED. THE GARAGE TO HOUSE DOOR WILL BE A STEEL DOOR TO MAINTAIN THE REQUIRED 20 MIN. FIRE SEPARATION.

INSTALLED @ 34" ABOVE THE STAIR MEASURED

VERTICALLY FROM THE STAIR TREAD, WITH

SPACER U.N.O. THE GARAGE DOOR HEADER WILL BE 2-14" MICRO LAMS (LOAD BRG WALL) OR 2-2X12 HEADER (NON-LOAD BRG WALL)

5. ALL WALLS WILL BE 2X4 @ 16" C/C AND EXTERIOR WALLS WILL BE SHEATHED WITH 7/16" OSB SUBSIDING AS A WINDBRACE.U.N.O. ROOF WILL BE TRUSSES COMPLETELY WITH 7/16" OSB SHEATHING AND PLY CLIPS AS REQUIRED.

6. INSULATION AND FACING EXPOSED IN ATTIC, DWELLING UNITS OR CRAWL SPACES SHALL HAVE A FLAME SPREAD RATING NOT TI EXCEED 25 AND SMOKE DEVELOPED FACTOR NOT TO EXCEED 450.

7. 2X BLOCKING EQUAL TO THE JOIST TO BE INSTALLED @ 24" O/C BETWEEN THE BAND AND FIRST JOIST WHICH IS PARALLEL TO THE FOUNDATION WALL. BLOCKING SHALL BE ADEQUATELY FASTENED TO THE FLOOR SHEATHING.

8 PERCENT OF FLOOR AREA OF SUCH ROOMS ONE HALF OF THE REQUIRED AREA OF GLAZING SHALL BE OPENABLE ATTIC VENTILATION SHALL BE 1 SQUARE FOOT FOR

EVERY 300 SQUARE FEET OF ATTIC SPACE, PROVIDING THAT VENTILATORS ARE INSTALLED IN THE UPPER PORTION OF THE SPACE

DESIGN LOADS

FLOOR LOAD -SOIL BEARING = 1500 LBS

ROOF LOADS = 16 PSF FLR (NON SLEEPING RMS) = 40 PSF ATTIC LOADS WITHOUT STORAGE = 10 PSF FLR (SLEEPING RM) = 30 PSF LIMITED STORAGE = 20 PSF

DECKING = 50 PSF (ADD 50 PSF IN AREA W/ HOT TUB)

I		REVISIONS
	NFW ADDITION TO	1 REV 9-18-18
	NEW ADDITION TO	2 REV 2-11-19
	FXISTING RESIDENCE	3 REV 2-13-19
	EMISTING NESIDENCE	PROJECT NO. CHRISTENSEN18
		DATE 8-6-18
	DLR DRAFTING SERVICE (937)360-7490 SPRINGFIELD, OHIO	A-1

