

## Addendum # 1 -- 19-007.0-CIP -- E-Mail Coversheet 2019 Bridge Maintenance

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Builders Exchange	info@bxohio.com	Kristin Niemeyer
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	David Power
Complete General Construction Comp	estimators@cgclist.com	Whit Wardell
ConstructConnect	content@constructconnect.com	Morgan Stinson
Construction Journal	loreen.white@constructionjournal.com	Doreen White
Danbert Electric	dtaylor@danbertinc.com	Don Taylor
Double Z Construction	vinceguzzo@doublez.co	Vince Guzzo
IMS	Dodge13@imsinfo.com	Shankar S
Jess Howard	ISTY.GUTRIDGE@JESSHOWARD.C	Christy Gutridge
Lake Erie Construction	sales@lec-co.com	Diana Coffman
North America Procurement Council In	lyra@napc.me	Lyra deAsis
Strawser Paving Company, Inc.	clayS@strawserpaving.com	Clay Strawser
The Blue Book	kstein@mail.thebluebook.com	Kathy Stein
The Righter Company, Inc.	bill@rightercompany.com	Bill Wyner
Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran

Please sign, date and return by e-mail to [hgeorge@dublin.oh.us](mailto:hgeorge@dublin.oh.us) to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: \_\_\_\_\_ Date: \_\_\_\_\_



Date of Addendum  
**Jul 03, 2019**

**City of Dublin -- Division of Engineering**  
5800 Shier-Rings Road Dublin OH 43016  
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 1  
to the contract for**

**2019 BRIDGE MAINTENANCE – FRANTZ ROAD AT COSGRAY CREEK  
19-007-CIP**

**Bid Date: July 11, 2019**

**TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:**

***Request for Information:***

- 1. Question:** Will we be able to use precast wing-walls, headwalls, and footings, in place of cast-in-place concrete?

*Answer:* Precast wing-walls, headwalls, and footings are not permitted. Contractor shall use cast-in-place reinforced concrete wing-walls, headwalls, and footings.

**Addendum Approved By:**

Paul A. Hammersmith, PE  
Director of Engineering/City Engineer

07-03-2019  
Date

\* \* \* \* \*

**Terminus for Addendum No. 1  
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 1 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

**Signed:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Company:** \_\_\_\_\_