

Addendum # 3 -- 18-019.0-CIP -- E-Mail Coversheet Sewer Line Extensions - Area 4B & 4C

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
Allied Construction Industries	klane@aci-construction.org	Kayla Lane
Builders Exchange	kniemeyer@bxohio.com	Kristin Niemeyer
Columbus Asphalt Paving, Inc.	dpower@capasphalt.com	David Power
Complete General Construction Comp	estimators@cgclist.com	Whit Wardell
Conie Construction Company	billo@conie.com	Bill O'Malley
ConstructConnect	content@constructconnect.com	Morgan Stinson
Core and Main	eben.miles@coreandmain.com	Eben Miles
Danbert Electric	jwilt@danbertinc.com	Jessica Wilt
Danbert Inc.	lsutton@danbertinc.com	Luke Sutton
DODGE Data & Analytics	dodge.bidding@construction.com	Dodge Analytics
Elite Excavating Company of Ohio, Inc	dalestevens@eliteexcavating.com	Dale Stevens
George J. Igel & Company, Inc.	matt.check@igelco.com	Matt Check
GreenScapes Landscape Co.	tomkuhn@greenscapes.net	Thomas Kuhn
IMS	bid_research@imsinfo.com	Bid Research
JMT	dbehanna@jmt.com	Davine Behanna
John Eramo & Sons, Inc.	jason@eramo.com	Jason Hazelbaker
Mt. Carmel Stabilization Group	mleedy@mtcsg.net	Marthy Leedy
National Trench Safety	jaredbozarth@ntsafety.com	Jared Bozarth

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 12, 2019

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 3 -- 18-019.0-CIP -- E-Mail Coversheet Sewer Line Extensions - Area 4B & 4C

Nickolas Savko and Sons	bthies@nicksavko.com	Vince Dabo
North America Procurement Council In	lyra@napc.me	Lyra de Asis
Shelly & Sands, Inc.	j.schultz@shellyandsands.com	Jeff Schultz
Shelly Materials	JGARRISON@shellyco.COM	Shelly Materials Col
Strawser Paving Company, Inc.	clayS@strawserpaving.com	Clay Strawser
The Blue Book Building & Construction	projectleads@mail.thebluebook.com	Manas Das
Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Nov 12, 2019

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 3
to the contract for**

**SANITARY SEWER EXTENSIONS AREAS 4B, 4C;
WATER LINE EXTENSIONS AREAS 4B, 4C AND BRIGHT ROAD CUL-DE-SAC
18-019.0-CIP, 18-020.0-CIP**

Revised Bid Date: November 20, 2019

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

Request for Information:

1. *Will 912 backfill be required for conduits regardless if it's not in the zone of influence of pavements?* Answer: All 6-inch, 8-inch, 12-inch water line; and 8-inch sanitary sewer shall have Item 912 backfill as specified in the construction drawings. The 3" water service sleeve and ¾" water service tap, complete, shall have Item 912 backfill under all existing pavement areas and at least to the influence line of existing pavement.
2. *Pavement widths shown on the plans seem to be wider than anticipated, does the contractor have to follow these widths or can the trenches be narrower for installments?* Answer: Contractor may use narrower trench widths down to the widths listed in the trench details in the construction drawings.
3. *The bid quantity for 12" ductile water possible did not include the 25' from the reducer to the plug on Bright Road.* Answer: The 25' length has been added to the revised Bid Schedule dated November 12, 2019.
4. *Why are the 6" sanitary services remaining extremely deep? In some cases they are 15' to 20' deeper than the first floor elevation. Can ending elevations be adjusted and the contractor be allowed to use risers?* Answer: 6" sanitary services ending elevations cannot be adjusted and risers shall not be permitted. The sanitary sewer has a depth to allow for the 6" sanitary services to cross under existing Billingsley Creek and/or allow for basement service.
5. *Will the contractor be required to core/boot the existing sanitary manhole for the connection points located on Sheets #20 & 21 or is there a hole already established?* Answer: The contractor shall core and boot the sanitary connection to an existing manhole with a flexible watertight joint conforming to Item 706.16 and as described in Item 604.06 for existing Manhole No. 20

*** Beginning of Sheet 2 ***

on Macbeth Drive. The existing Manhole No. S20 on Jenmar Court has an existing 8-inch stub – no core or boot necessary at this existing manhole.

6. *In regards to Waterline Extension bid item #14 "Emergency Siren Pole Removed and Reset", it has come to my attention that the Siren Pole is most likely the property of the Franklin County Emergency Management Agency and that they directly contract with a local electrician to remove/reset/maintain/etc. these poles. Can you confirm if this work will be under this bid contract or if it will be handled by a third party/Franklin Co Emergency.* Answer – City of Dublin owns and maintains this emergency siren pole. Ref. No. 14, Item 202 - Emergency Siren Pole Removed and Reset, to be bid and is part of the construction documents.

SECTION 2 –BIDDING FORMS

A few bid quantities, such as topsoil and seeding, appeared as whole numbers in the bid schedule but were decimal numbers. The bid schedule has been revised to reflect whole numbers for these quantities.

Page 26-4: Change Reference No. 49
ITEM 801 12" WATER PIPE AND FITTINGS 75 LF
To Reference No. 49
ITEM 801 12" WATER PIPE AND FITTINGS 100 LF

Remove ALL Bid Schedule Sheets 26-1 through 26-10 dated October 30, 2019 and replace them with Bid Schedule Sheets 26-1 through 26-10 dated November 12, 2019.

Addendum Approved By: 
Paul A. Hammersmith, PE 11-12-2019
Director of Engineering/City Engineer Date

* * * * *

**Terminus for Addendum No. 3
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 3 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____ **Date:** _____

Company: _____