

Addendum # 2 -- 20-024.0-CIP -- E-Mail Coversheet

Sanitary Sewer Extension - Areas 1B and 1C

<i>Planholder</i>	<i>Company E-Mail</i>	<i>Company Contact</i>
ABM	doug.krumrei@abm.com	Doug Krumrei
Allied Construction Industries	klane@aci-construction.org	Kayla Lane
Bidnet	mary-ellen.testa@mdfcommerce.com	Mary Ellen Testa
Builders Exchange	adaniels@bxohio.com	Allyson Daniels
Builders Exchange	adaniels@bxohio.com	Allyson Daniels
Complete General Construction Comp	wwardell@completegeneral.com	Whit Wardell
ConstructConnect	content@constructconnect.com	Morgan Stenson
Culy Contracting, INC	Leyton.peavler@culycontracting.com	Leyton Peavler
Driven Excavating LLC	darrin@drivenexcavating.com	Darrin Feichtner
Elite Excavating Company of Ohio, Inc	dalestevens@eliteexcavating.com	Dale Stevens
George J. Igel & Company, Inc.	matt.check@igelco.com	Matthew Check
IMS	ims_bids@construction.com	bid research
John Eramo & Sons, Inc.	jason@eramo.com	Jason Hazelbaler
MCSP	dave@mcspinc.com	Dave Steel
Midwest Mole Inc	plandesk@midwestmole.com	Amy Webster
Nickolas Savko and Sons	jp Piccin@nicksavko.com	John Piccin
North America Procurement Council In	lyra@napc.me	Lyra deAsis
Strawser Paving Company, Inc.	clayS@strawserpaving.com	Clay Strawser

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Jun 09, 2021

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

Addendum # 2 -- 20-024.0-CIP -- E-Mail Coversheet

Sanitary Sewer Extension - Areas 1B and 1C

The Blue Book	kstein@mail.thebluebook.com	Kathy Stein
The Kleingers Group	mike.couvreur@kleingers.com	Michael Couvreur
The Olen Corporation	twr@theolencorp.biz	Tim Rhodes
Trucco Construction Company	joel.cochran@truccoconstruction.com	Joel Cochran

Please sign, date and return by e-mail to hgeorge@dublin.oh.us to verify receipt of this addendum. Attach signed copy of addendum to bid package when submitting a bid.

Received by: _____ Date: _____



Date of Addendum
Jun 09, 2021

City of Dublin -- Division of Engineering
5800 Shier-Rings Road Dublin OH 43016
Phone (614) 410-4640 Fax (614) 761-650

**ADDENDUM NO. 2
to the contract for**

**SANITARY SEWER EXTENSION AREA 1C
20-024-CIP**

Bid Date: June 10, 2021

TO PROSPECTIVE BIDDERS: The following changes shall be made part of the contract documents for this project:

Request for Information:

1. *Can you please clarify what type of 703.11 backfill can be used? Typically you don't allow type 2 as stated in the general notes.*

Answer: Granular backfill shall be compacted granular material according to Item 912 of the standard specifications or low strength mortar backfill according to Item 613, Type 2 of the standard specifications as directed by the City Engineer.

Detail 8/4 on Sheet 4 of 23 specifies Item 304, Compacted Granular Material for trench backfill material (Item 912). Item 703.11 Structural Backfill Type 1 shall be used. Item 703.11 Structural Backfill Type 2 is not approved and shall not be used.

Addendum Approved By:



Paul A. Hammersmith, PE
Director of Engineering/City Engineer

6-9-2021
Date

* * * * *

**Terminus for Addendum No. 2
Certification by Bidder**

Bidder shall sign and date one copy of this Addendum No. 2 and submit with his proposal as evidence of receipt and evaluation of same in his bid analysis.

Signed: _____

Date: _____

Company: _____